

## **King William County Lighting Project-Phase 1-revised**

King William County is converting its existing T-12 fluorescent lighting with an LED lighting product. Phase One (Administration Building) light fixtures consist of four (4) foot, two (2) foot, and two (2) foot U-tube fluorescent lamps. This project is expected to span a five (5) year period and will replace all King William County lighting by purchase of LED Lighting.

The LED product chosen must meet minimum UL and DLC certification and be rated for 100-277 voltage. The LED product must have an internal driver and be warrantied for five (5) years. All lamps are to be 5000K.

The LED products must be meet the specifications as manufactured by IBA LED models as follows or equal:

WTG T8 LED Tube four (4) foot with internal driver model # R-01118-18 watt. 960 four foot tubes required.

T8 LED Tube two (2) foot with internal driver model # R-01110-1-10 watt. 10 two foot tubes required.

Instant fit two (2) foot U bend T8 LED tube model # R-01112-FR-U-18 watt. 14 two foot U tubes required.

Include manufacturer specifications for each tube. Manufacturer shall have been in business a minimum of ten (10) years.

All quotes are due by noon (12:00 PM) on Monday, April 4, 2016. Submit quotes on eVA Quick Quote site or in writing to King William County Finance Office, c/o Beth Dandridge, 180 Horse Landing Road #4, King William, VA 23086.